

**TECHNICAL EVALUATION REPORT OF BIDDERS' ELIGIBILITY / RESPONSIVENESS
SUPPLY / FIXING / INSTALLATION / COMMISSIONING OF HAVC FOR 3RD & 4TH FLOOR
OF SEROBIOLOGY BUILDING ON (TURNKEY BASIS) AT OJHA CAMPUS, DUHS, KARACHI.
REF: DUHS/W&S/2019/059, NIT No. DUHS/ W&S /2019/12. Dated 21 November 2019
Technical Bids Opened on 16 December 2019 AT 11:30 A.M.**

A. PRODUCT EVALUATION

PARAMETERS / SUB-PARAMETERS

MANDATORY REQUIREMENT FOR TECHNICAL EVALUATION FOR ELIGIBLE BIDDERS / QUALIFICATION CRITERIA

ITB Clause	Technical Evaluation Parameters	Total Marks	M/s MIA Corporation.	M/s Habibullah Associates (Pvt) Ltd.	(Joint Venture) M/s NTT Inc. (Lead Member) Annam International. (Member)	M/s Annam International.	M/s Graves Pakistan.
1	Conformity to the Purchaser's Specifications (Mandatory)	25	0	0	0	0	
1.1	Fully compliant with the required specifications	25					
1.2	Compliant with minor deviation (up to 10% subject to main function is not affected)	20					
1.3	Non-compliant to required specifications	Disqualify	Disqualify	Disqualify	Disqualify	Disqualify	
2	Product Certification	15	8	0	0	0	
2.1	USA Food & Drug Administration (USA-FDA) and European Community (CE) MDD or Japan Industrial Standard (JIS) / Cooling Technology Institute (CTI) / Japan Quality Assurance Organization (JQAO) / Certificate issued by Ministry of Health, Labour and Welfare Govt. of Japan	15					Vendor refused to quote this project vide letter no GAPL/TENDER/19/KH/S-MR dated 29/11/2019
2.2	European Community (CE) MDD and Japan Industrial Standard (JIS) / Japan Quality Assurance Organization (JQAO) / Certificate issued by Ministry of Health, Labour and Welfare Govt. of Japan	12					
2.3	USA - Food and Drug Administration (USA-FDA)	10					
2.4	European Community (CE) MDD	8	8	0	0	0	
2.5	Japan Industrial Standard (JIS) / Japan Quality Assurance Organization (JQAO) / Certificate issued by Ministry of Health, Labour and Welfare Govt. of Japan	8					
	TOTAL MARKS PRODUCT EVALUATION (A)	40	33	0	0	0	0

Abdurrahim Khan
Project Director
Planning & Development Department
Dow University of Health Sciences
Karachi.

Sufyan Aslam Khan
Manager Services
Dow University of Health Sciences,
Karachi

Sr. Iqbal

Muhammad Khuram Khalid
Head of Internal Audit
Institute of Business Administration
Karachi.

Prof. Khawar-Saeed Jamali
Pro-Vice Chancellor
Dow University of Health Sciences
Karachi-Pakistan.



B. BIDDER EVALUATION

PARAMETERS / SUB-PARAMETERS

ITB Clause	Technical Evaluation Parameters	Total Marks	M/s MIA Corporation.	M/s Habibullah Associates (PVT) LTD.	(Joint Venture) M/s NTT Inc. (Lead Member) Annam International (Membre)	M/s Annam International	M/s Graves Pakistan.
3	Manufacturer's Authorization (Mandatory)	10	10	0	0	0	
3.1	Valid Authorization of Manufacturer of goods	10	10				
3.2	Non-submission of valid manufacturer's authorization	Disqualify		Disqualify	Disqualify	Disqualify	
4	Legal Requirement (Mandatory)	8	8	8	8	8	
4.1	Bid Form (without prices)	2	2	2	2	2	
4.2	Tender Purchase Receipt	2	2	2	2	2	
4.3	Taxation Certificate (NTN and GST)	2	2	2	2	2	
4.4	Affidavit on Stamp Paper of Rs. 100/- that Bidder is not involved in any litigation with the Public / Private Sector University / Government / Semi Government Organization (Provincial / Federal / Local) Bidder is not black listed by any Public / Private Sector University / Government / Semi Government Organization (Provincial/Federal / Local).	2	2	2	2	2	Vendor refused to quote this project vide letter no GAPL/TENDER/19/KH/S MR dated 29/11/2019
5	Technical Staff	10	6	0	4	0	
5.1	Diploma Engineers in relevant field duly trained by OEM for required equipment (2 mark for each)	4	2	(OEM training Certificates not attached)	2	(OEM training Certificates not attached)	
5.2	Graduate Engineers in relevant field duly trained by OEM for required equipment (2 marks for each)	6	4	(OEM training Certificates not attached)	2	(OEM training Certificates not attached)	

Dr. F. J. J. J.




Abdul Rahim Khan
 Manager Services
 Dow University of Health Sciences,
 Karachi


Abdul Rahim Khan
 Project Director
 Planning & Development Department
 Dow University of Health Sciences
 Karachi.

Muhammad Khurram Khalid
MUHAMMAD KHURRAM KHALID
 Prof. Khawar Saeed Jamali
 Pro-Vice Chancellor
 Head of Internal Audit
 Dow University of Health Sciences
 Karachi-Pakistan.
 Institute of Business Karachi.


ITB Clause	PARAMETERS / SUB-PARAMETERS	Total Marks	M/s MIA Corporation.	M/s Habibullah Associates (PVT) LTD.	(Joint Venture) M/s NTT Inc. (Lead Member) / Annam International. (Member)	M/s Annam International.	M/s Graves Pakistan.
6	Networking and Training	6	6	5	5	5	0
6.1	Networking setup across Pakistan (1 mark for each setup)	4	4	3	3	3	
6.2	Certificate to affect that the firm will provide training in the use of equipment to the relevant technical staff. Training plan must be attached with certificate	2	2	2	2	2	
7	Delivery Schedule at consignees end	4	4	4	4	4	
7.1	Up to 5 months or earlier (CFR / CNE/ C&F / CPT or DDP)	4	4	4	4	4	
7.2	More than 5 months	0					
8	Past Experience / Performance of Last 3 years	5	3	0	1	0	
8.1	Bidder's prior experience for supplying the quoted or better equipment to the Public / Private Sector Universities / Government / Semi-Government Organization (Provincial / Federal / Local) in Pakistan during the last 3 years. Documentary evidence in shape of Purchase Order and Installation Report / Satisfactory performance certificate must be attached. (1 mark for supply of each equipment / instrument)	5	3	0	1 (with out submitted Installation Report)	0	
9	Average Annual Turnover during the last three (03) years (financial year 2015-16, 2016-17 & 2017-18)	8	8	8	2	0	Vendor refused to quote this project vide letter no GAPL/TENDER/19/KH/S MR dated 29/11/2019
9.1	Turn over below 50 million	0				0	
9.2	Turn over above 50 million	2			2		
9.3	Turn over above 100 million	4					
9.4	Turn over above 150 million	8	8	8			
10	Financial Statements for financial year 2015-16, 2016-17 & 2017-18	4	4	4	4	4	
10.1	Audited statement of Accounts, for last three years	2	2	2	2	2	
10.2	Provision of copy of Income Tax Return Forms, for last three years	2	2	2	2	2	
11	Bonus points	5	2	0	2	2	
11.1	Extended Warranty period free of cost (at least one year) (the bidder who offered greater period will get the marks)	5	2	1	2	2	
TOTAL BIDDER EVALUATION (B)		60	51	29	30	23	
GRAND TOTAL (A + B)		100	84	29	50	23	
REMARKS			Qualified	Disqualified	Disqualified	Disqualified	Disqualified



Aslam Khan
 Project Director
 Planning & Development Department
 Dow University of Health Sciences



Muhammad Khuram Khalid
 Head of Internal Audit
 Institute of Business Administration
 Karachi - Pakistan.




 University of Health Sciences
 Finance Directorate
 Karachi

SUPPLY / FIXING / INSTALLATION / COMMISSIONING OF HVAC FOR 3RD & 4TH FLOOR OF SEROBIOLOGY BUILDING ON (TURNKEY BASIS) AT OJHA CAMPUS, DUHS, KARACHI.


M/s MIA Corporation (Pvt) Ltd.

GROUP-A


S. No	DESCRIPTION	Units	QTY	Eligible Bidders / Technical Qualification Criteria	
				Observation	Remarks
1	Supply of Centrifugal Oil Free Magnetic Bearing Water Cooled Chiller with VFD and Controls including supply of following essential spare parts as supplied with chiller. (a) Centrifugal Compressor (One No.) (b) Switchboard (One No.) (c) Graphical Panel (One No.) As shown on the drawings, as specified in equipment schedule and as per technical specification including all material and accessories, complete in all respect and to the satisfaction of Engineer incharge. ARI / AHRI Certification Required. Make: Europe / Japan / USA.	3	4		
2	Supply of Cross Flow Closed Type Cooling Towers, as shown on the drawings, as specified in equipment schedule and as per technical specifications including all material and accessories, complete in all respect and to the satisfaction of Engineer incharge. CTI / JIS / JCI Certification Required Make: Europe / Japan / USA.	Nos	2	(a) Data Sheet Offered Model, Water cool centrifugal Chiller, WMC048DD Daikin made in USA.	Ok
3	Supply of Air Handling Units as shown on the drawings, as specified in equipment schedule and as per technical specifications including all material, volume control dampers and accessories, complete in all respect and to the satisfaction of Engineer incharge. EUROVENT/AHRI Certification and Hygiene Certification Required (Mandatory) Make: Europe / Japan / USA.	Nos	2	(a) Data Sheet, Offered Model, Marley (Closed type Model MHF7101PAEENC5)SPX cooling technology, made in USA. CTI USA Certificate Photocopy, Validity november 10 2017 (b) Distributorship Certificate (Malaysia), validity 24 February 2019. (c) Hygiene Certificate Germany 4 November 2016	Ok
4	Supply of Fan Coil Units Cassette type, as shown on the drawings, as specified in equipment schedule and as per technical specifications including all material and accessories, complete in all respect and to the satisfaction of Engineer incharge. EUROVENT/AHRI Certification Required (Mandatory) Make: Europe / Japan / USA.	Nos	120	(a) Data Sheet, Offered Model, Action Clima Model FCS 430 (2 Pipes), Model FCS 1230 (2 pipes), Model FCS 1430 (2 pipes), Model FCS 830 (2 pipes), made in Italy, 1430 (2 pipes), Model FCS 830 (2 pipes), made in Italy, (b) MIA Corporation, Authorized Distributor for the year 2019, model certificate FCS 01 - 07 - 2021	Ok




Abdullah Khan
 Project Director
 Planning & Development Department
 Dow University of Health Sciences
 Karachi.




Irfan Iqbal Khan
 Manager Services
 Dow University of Health Sciences,
 Karachi.



MUHAMMAD HURRAIN KHATTAK
 Head of Internal Audit
 Institute of Business Administration
 Karachi.




Khawar Saeed Jamali
 Pro-Vice Chancellor
 University of Health Sciences
 Karachi-Pakistan.



 Director of Finance & Accounts


SUPPLY / FIXING / INSTALLATION / COMMISSIONING OF HVAC FOR 3RD & 4TH FLOOR OF SEROBIOLOGY BUILDING ON (TURNKEY BASIS) AT OJHA CAMPUS, DUHS, KARACHI.

(Joint Venture) M/s NTI Inc. (Pvt) Ltd. (Lead Member) & M/s Annam International (Pvt) Ltd. (Member)

S. No	DESCRIPTION	Units	QTY	Eligible Bidders / Technical Qualification Criteria	Remarks
1	Supply of Centrifugal Oil Free Magnetic Bearing Water Cooled Chiller with VFD and Controls including supply of following essential spare parts as supplied with chiller. (a) Centrifugal Compressor (One No.) (b) Switchboard (One No.) (c) Graphical Panel (One No.) As shown on the drawings, as specified in equipment schedule and as per technical specification including all material and accessories, complete in all respect and to the satisfaction of Engineer incharge. ARI / AHRI Certification Required. Make: Europe / Japan / USA.	3	4	(a) Offered GEOLIMA Model TMH 28850 WT -34 GEOLIMA SRL UNIPERSONALE TURBOWISER RANGE CHILLERS (Model TMH - 34) made in Italy, (b) Photocopy AHRI certificate 8-6-2019), verified from principal through email vide dated 18/02/2020	Ok
2	Supply of Cross Flow Closed Type Cooling Towers, as shown on the drawings, as specified in equipment schedule and as per technical specifications including all material and accessories, complete in all respect and to the satisfaction of Engineer incharge. CTI / JIS / JCI Certification Required Make: Europe / Japan / USA.	Nos	2	(a) KUKEN Cooling tower: Series 01, (Closed type) made in Japan, (b) Photocopy JCI Certificate 25 March 2015, (c) Manufacturing Authorization Certificate Not verified by the principal	Reject
3	Supply of Air Handling Units as shown on the drawings, as specified in equipment schedule and as per technical specifications including all material, volume control dampers and accessories, complete in all respect and to the satisfaction of Engineer incharge. EUROVENT/AHRI Certification and Hygiene Certification Required (Mandatory) Make: Europe / Japan / USA.	Nos	4	(a) GEOLIMA offered Model TW26P5EBI, SRL UNIPERSONALE, I-34077 RONCHI RELEGIONARI Central station Air Handling Unit, Multicent Type TW Certificate photocopies, Ternitz, Josef Huber str. - 6 (Italy) (b) Photocopy certificate 31-3-2019: (EUROVENT) (c) Photocopy for Hygiene in AHU dated 27-12-2016, (d) Certificate verified from principal through email vide dated 18/02/2020, Variable Frequency Drive (VFD) is not mention in data sheet Group B, S#3 Ref: NIT page 7 of 126 (Technical Data Sheet)(Confirmation Required from the vendor	Ok
4	Supply of Fan Coil Units Cassette type, as shown on the drawings, as specified in equipment schedule and as per technical specifications including all material and accessories, complete in all respect and to the satisfaction of Engineer incharge. EUROVENT/AHRI Certification Required (Mandatory) Make: Europe / Japan / USA.	Nos	3	(a) ACCADEMIA AC Brand Tononforty, made in Italy, (b) Model not define. (c) Manufacturing Authorization Certificate Not Submitted (Mandatory)	Reject


Abdul Raheem Khan
 Project Director
 Planning & Development Department
 Dow University of Health Sciences
 Karachi.


Prof. Khawar Saeed Jamali
 Vice-Chancellor
 Dow University of Health Sciences
 Karachi-Pakistan.


MUHAMMAD YUNUS RAM KHALID
 Head of Internal Audit
 Institute of Business Administration
 Karachi.

SUPPLY / FIXING / INSTALLATION / COMMISSIONING OF HVAC FOR 3RD & 4TH FLOOR OF SERO BIOLOGY BUILDING ON (TURNKEY BASIS) AT OJHA CAMPUS, DUHS, KARACHI.

M/s Annam International

GROUP-A

S. No	DESCRIPTION	Units	QTY	Eligible Bidders / Technical Qualification Criteria		Remarks
				Observation		
1	Supply of Centrifugal Oil Free Magnetic Bearing Water Cooled Chiller with VFD and Controls including supply of following essential spare parts as supplied with chiller. (a) Centrifugal Compressor (One No.) (b) Switchboard (One No.) (c) Graphical Panel (One No.) As shown on the drawings, as specified in equipment schedule and as per technical specification including all material and accessories, complete in all respect and to the satisfaction of Engineer incharge. ARI / AHRI Certification Required. Make: Europe / Japan / USA. Supply of Cross Flow Closed Type Cooling Towers , as shown on the drawings, as specified in equipment schedule and as per technical specifications including all material and accessories, complete in all respect and to the satisfaction of Engineer incharge. CTI / JIS / JCI Certification Required Make: Europe / Japan / USA.	3	4			
1	Supply of Fan Coil Units as shown on the drawings, as specified in equipment schedule and as per technical specifications including all material, equipment control dampers and accessories, complete in all respect and to the satisfaction of Engineer incharge. EUROVENT/AHRI Certification and Hygiene Certification Required (Mandatory) Make: Europe / Japan / USA.	Nos	2		a) Offered GEOCLIMA Model TMH 28850 WT-34 GEOCLIMA SRL UNIPERSONALE TURBOMISER RANGE CHILLERS (Model TMH - 34) made in Italy. (b) Photocopy AHRI certificate 8-6-2019. Certificate Dubious need to be verify from principal (c) Certificate dubious not verified by principal	Reject
2	Supply of Air Handling Units as shown on the drawings, as specified in equipment schedule and as per technical specifications including all material, equipment control dampers and accessories, complete in all respect and to the satisfaction of Engineer incharge. CTI / JIS / JCI Certification Required Make: Europe / Japan / USA.	Nos	2		(a) KUKEN Cooling tower, Series 01, (Closed type) made in Japan, (b) Photocopy JCI Certificate 25 March 2015, (c) Certificate dubious not verified by principal.	Reject
3	Supply of Fan Coil Units as shown on the drawings, as specified in equipment schedule and as per technical specifications including all material, equipment control dampers and accessories, complete in all respect and to the satisfaction of Engineer incharge. EUROVENT/AHRI Certification and Hygiene Certification Required (Mandatory) Make: Europe / Japan / USA.	Nos	4		(a) GEOCLIMA offered Model TW26P5EBI, SRL UNIPERSONALE, I-34077 RONCHI REI LEGIONARI Central station Air Handling Unit, Multicent Type TW Certificate photocopies, Ternitz, Josef Huber str. - 6 (Italy) (b) Photocopy certificate 31-3-2019, (EUROVENT) (c) Photocopy for Hygiene in AHU dated 27-12-2016, (d) Certificate dubious not verified by principal/Variable Frequency Drive (VFD) is not mention in data sheet Group B, SRS Ref: NIT page 7 of 126 (Technical Data Sheet) Confirmation Required from title vendor	Reject
4	Supply of Fan Coil Units as shown on the drawings, as specified in equipment schedule and as per technical specifications including all material and accessories, complete in all respect and to the satisfaction of Engineer incharge. EUROVENT/AHRI Certification Required (Mandatory) Make: Europe / Japan / USA.	Nos	120		(a) ACCADEMIA AC, Brand Tomonforty, without model, made in Italy, (b) Certificate dubious not verified by principal	Reject


Abdul Raheem Khan
 Project Director
 Planning & Development Department
 Dow University of Health Sciences
 Karachi.


MUHAMMAD KHURRAM KHALID
 Head of Internal Audit
 Institute of Business Administration
 Karachi.


Prof. Khayyar Saeed Jamali
 Pro-Vice Chancellor
 Dow University of Health Sciences
 Karachi-Pakistan.



SUPPLY / FIXING / INSTALLATION / COMMISSIONING OF HVAC FOR 3RD & 4TH FLOOR OF SEROBIOLOGY BUILDING ON (TURNKEY BASIS) AT OJHA CAMPUS, DUHS, KARACHI.

M/s Habibullah Associates (Pvt) Ltd

GROUP-A

S. No	DESCRIPTION	Units	QTY	Eligible Bidders / Technical Qualification Criteria	
				Observation	Remarks
1	Supply of Centrifugal Oil Free Magnetic Bearing Water Cooled Chiller with VFD and Controls including supply of following essential spare parts as supplied with chiller. (a) Centrifugal Compressor (One No.) (b) Switchboard (One No.) (c) Graphical Panel (One No.) As shown on the drawings, as specified in equipment schedule and as per technical specification including all material and accessories, complete in all respect and to the satisfaction of Engineer incharge. ARI / AHRI Certification Required. Make: Europe / Japan / USA.	3	4	(a) Offered Model/Carrier Model 19PVI1010 (274 Ton) made in France, AH Carrier. Fx: UAE. Authorization Certificate Not Submitted By M/s Habibullah Associates Pvt Ltd (b) M/s Smart Climate Solution is Partner in Pakistan through email vide dated 18/02/2020	Reject
1	Supply of Cross Flow Closed Type Cooling Towers, as shown on the drawings, as specified in equipment schedule and as per technical specifications including all material and accessories, complete in all respect and to the satisfaction of Engineer incharge. CTI/ JIS / JCI Certification Required. Make: Europe / Japan / USA.	Nos	2	(a) Offered Shinwa cooling tower cross flow square tank EBARA Model MKC-U, 550 ASW, made in Japan. (b) Authorize Distributor MRC Engineering authorize to Habibullah Associate Sub Let BY MRC Engineering. (c) Authorization Certificate Not Submitted By M/s Habibullah Associates Pvt Ltd	Reject
2	Supply of Air Handling Units as shown on the drawings, as specified in equipment schedule and as per technical specifications including all material, volume control dampers and accessories, complete in all respect and to the satisfaction of Engineer incharge. EUROVENT/AHRI Certification and Hygiene Certification Required (Mandatory). Make: Europe / Japan / USA.	Nos	4	(a) Offered Carrier Model RAL 7035, FAHU-01-04, made in Turkey. (b) Occupational Health and Safety Management System (OHSMS), made in Turkey. (c) Hygiene Certification Not Submitted By M/s Habibullah Associates Pvt Ltd	Reject
3	Supply of Fan Coil Units Cassette Type, as shown on the drawings, as specified in equipment schedule and as per technical specifications including all material and accessories, complete in all respect and to the satisfaction of Engineer incharge. EUROVENT/AHRI Certification Required (Mandatory). Make: Europe / Japan / USA.	Nos	120	(a) Offered Model 42GW cassette fan coil with multi speed model 500 CA, 600 CA, 701 CA Carrier (2 pipe cooling) made in Czech Republic. (b) AH Carrier Fx: A Carrier Joint venture Company (UAE) (c) Authorization Certificate Not Submitted By M/s Habibullah Associates Pvt Ltd	Reject

Abdul Rahim Khan
Project Director
Planning & Development Department
Dow University of Health Sciences
Karachi.

Muhammad Khuram Khalid
Head of Internal Audit
Institute of Business Administration
Karachi.



Prof. Khawar-Saeed Jamali
Pro-Vice Chancellor
Dow University of Health Sciences
Karachi-Pakistan.